

Coefficienti di utilizzazione

| R | 77 | 75 | 73 | 71 | 55 | 53 | 33 | 00 | DRR |
|------|----|----|----|----|----|----|----|----|-----|
| K0.8 | 72 | 67 | 63 | 61 | 66 | 63 | 62 | 59 | 70 |
| 1.0 | 76 | 71 | 68 | 65 | 70 | 67 | 67 | 63 | 76 |
| 1.5 | 81 | 77 | 74 | 72 | 76 | 73 | 72 | 69 | 83 |
| 2.0 | 84 | 81 | 79 | 77 | 80 | 78 | 77 | 73 | 88 |
| 2.5 | 86 | 84 | 82 | 80 | 82 | 80 | 79 | 76 | 91 |
| 3.0 | 87 | 85 | 84 | 83 | 84 | 82 | 81 | 78 | 94 |
| 4.0 | 88 | 87 | 86 | 85 | 85 | 84 | 83 | 80 | 96 |
| 5.0 | 89 | 88 | 87 | 87 | 86 | 85 | 84 | 81 | 97 |

Curva limite di luminanza



Diagramma UGR

| Corrected UGR values (at 1050 lm bare lamp luminous flux) | | | | | | | | | | | |
|--|------|---------------------|------|------|------|------|-------------------|------|------|------|------|
| Reflect.: ceiling/cav walls work pl. Room dim x y | | viewed crosswise | | | | | viewed endwise | | | | |
| | | 0.70 | 0.70 | 0.50 | 0.50 | 0.30 | 0.70 | 0.70 | 0.50 | 0.50 | 0.30 |
| | | 0.50 | 0.30 | 0.50 | 0.30 | 0.30 | 0.50 | 0.30 | 0.50 | 0.30 | 0.30 |
| | | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 |
| 2H | 2H | 14.2 | 14.8 | 14.5 | 15.1 | 15.4 | 14.5 | 15.1 | 14.8 | 15.4 | 15.6 |
| | 3H | 14.6 | 15.2 | 15.0 | 15.5 | 15.8 | 14.4 | 15.0 | 14.8 | 15.3 | 15.7 |
| | 4H | 14.9 | 15.5 | 15.3 | 15.8 | 16.1 | 14.4 | 15.0 | 14.8 | 15.3 | 15.6 |
| | 6H | 15.2 | 15.8 | 15.6 | 16.1 | 16.5 | 14.4 | 14.9 | 14.8 | 15.2 | 15.6 |
| | 8H | 15.4 | 15.9 | 15.8 | 16.3 | 16.7 | 14.4 | 14.9 | 14.8 | 15.2 | 15.6 |
| | 12H | 15.7 | 16.2 | 16.1 | 16.5 | 16.9 | 14.3 | 14.8 | 14.7 | 15.2 | 15.6 |
| 4H | 2H | 14.2 | 14.7 | 14.5 | 15.0 | 15.4 | 14.9 | 15.5 | 15.3 | 15.8 | 16.2 |
| | 3H | 14.8 | 15.2 | 15.2 | 15.6 | 16.0 | 15.1 | 15.5 | 15.5 | 15.9 | 16.3 |
| | 4H | 15.2 | 15.6 | 15.6 | 16.0 | 16.4 | 15.1 | 15.6 | 15.6 | 16.0 | 16.4 |
| | 6H | 15.7 | 16.0 | 16.1 | 16.5 | 16.9 | 15.2 | 15.6 | 15.7 | 16.0 | 16.5 |
| | 8H | 16.0 | 16.3 | 16.4 | 16.8 | 17.2 | 15.2 | 15.6 | 15.7 | 16.0 | 16.5 |
| | 12H | 16.4 | 16.7 | 16.9 | 17.1 | 17.6 | 15.2 | 15.5 | 15.7 | 16.0 | 16.5 |
| 8H | 4H | 15.3 | 15.6 | 15.7 | 16.0 | 16.5 | 15.4 | 15.8 | 15.9 | 16.2 | 16.7 |
| | 6H | 15.9 | 16.2 | 16.4 | 16.7 | 17.2 | 15.6 | 15.9 | 16.1 | 16.4 | 16.9 |
| | 8H | 16.3 | 16.6 | 16.9 | 17.1 | 17.6 | 15.7 | 15.9 | 16.2 | 16.4 | 17.0 |
| | 12H | 16.9 | 17.1 | 17.5 | 17.7 | 18.2 | 15.8 | 16.0 | 16.3 | 16.5 | 17.1 |
| 12H | 4H | 15.3 | 15.6 | 15.7 | 16.0 | 16.5 | 15.5 | 15.8 | 16.0 | 16.3 | 16.8 |
| | 6H | 16.0 | 16.2 | 16.5 | 16.7 | 17.2 | 15.7 | 16.0 | 16.3 | 16.5 | 17.0 |
| | 8H | 16.4 | 16.6 | 17.0 | 17.2 | 17.7 | 15.9 | 16.1 | 16.4 | 16.6 | 17.2 |
| Variations with the observer position at spacing: | | | | | | | | | | | |
| S = | 1.0H | 1.8 / -1.1 | | | | | 2.3 / -1.7 | | | | |
| | 1.5H | 3.5 / -1.3 | | | | | 4.4 / -2.0 | | | | |
| | 2.0H | 5.1 / -1.4 | | | | | 6.1 / -2.1 | | | | |