


Design iGuzzini iGuzzini

Product configuration: QL18.04
QL18.04: Minimal 10 cells - Flood - LED - Black



QL18.04: Minimal 10 cells - Flood - LED - Black

Linear miniaturised recessed luminaire with 10 optical elements for LED lamps - fixed optic. Die-cast aluminium body, minimal version (frameless) installed flush with ceiling. For recessed installation in a false ceiling a specific adapter is required that is available with a separate item code. Metallised thermoplastic high definition OptiBeam reflector, integrated in a rear position in the black anti-glare screen; the structure of the optical system prevents a pinpoint effect, allowing precise, circular light distribution and emission with controlled glare. Supplied with a dimmable DALI power supply unit connected to the luminaire. High colour rendering LED.

The recess body is inserted in the specific adapter installed previously by means of a steel wire spring - check the thickness of the false ceiling and use a compatible frame available with a separate item code.

Colour	Weight (Kg)
Black (04)	0.55

wall recessed|ceiling recessed

Quick-coupling connections on the ballast unit.

Complies with EN60598-1 and pertinent regulations



Im system:	1358	CRI (typical):	97
W system:	24.5	Colour temperature [K]:	2700
Im source:	1700	MacAdam Step:	3
W source:	21	Life Time LED 1:	50,000h - L90 - B10 (Ta 25°C)
Luminous efficiency (Im/W, real value):	55.4	Lamp code:	LED
Im in emergency mode:	-	Number of lamps for optical assembly:	1
Total light flux at or above an angle of 90° [Lm]:	0	ZVEI Code:	LED
Light Output Ratio (L.O.R.) [%]:	80	Number of optical assemblies:	1
Beam angle [°]:	31°	Control:	DALI-2
CRI (minimum):	95		

<p>A light distribution diagram (candela diagram) showing beam spread. The vertical axis represents height in meters (m), with markings at 0, 5000, and 10000. The horizontal axis represents distance in meters (m), with markings at -90°, 0°, and 90°. A central vertical line indicates the beam's path. At the top, it says "Imax=4660 cd". Below this, it lists CIE nL 0.80, 100-100-100-80, UGR <10<10, DIN A.61, UTE 0.80A-0.00T, F*1=1000, F*1+F*2=1000, and F*1+F*2+F*3=1000. At the bottom left, it says "α = 32°".</p>	CIE	Lux				
	nL 0.80 100-100-100-80 UGR <10<10					
	DIN A.61					
	UTE 0.80A-0.00T F*1=1000 F*1+F*2=1000 F*1+F*2+F*3=1000	h	d	Em	E _{max}	
		2	1.1	896	1165	
		4	2.3	224	291	
	6	3.4	100	129		
	CIBSE LG3 L<1500 cd/m² at 65° UGR<10 L<1500 cd/mq @65°	8	4.6	56	73	

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	72	69	66	64	68	66	65	63	78
1.0	75	72	70	68	71	69	69	66	83
1.5	79	77	75	73	76	74	73	71	89
2.0	81	80	78	77	79	77	76	74	93
2.5	83	82	81	80	80	79	79	77	96
3.0	84	83	82	81	82	81	80	78	98
4.0	85	84	84	83	83	82	81	79	99
5.0	85	85	85	84	84	83	82	80	100

UGR diagram

Corrected UGR values (at 1700 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	-3.5	-2.9	-3.2	-2.7	-2.5	-3.5	-2.9	-3.2	-2.7	-2.5
	3H	-3.6	-3.1	-3.3	-2.9	-2.6	-3.6	-3.1	-3.3	-2.9	-2.6
	4H	-3.7	-3.2	-3.3	-2.9	-2.6	-3.7	-3.2	-3.3	-2.9	-2.6
	6H	-3.7	-3.3	-3.4	-3.0	-2.7	-3.7	-3.3	-3.4	-3.0	-2.7
	8H	-3.8	-3.4	-3.4	-3.1	-2.7	-3.8	-3.4	-3.4	-3.1	-2.7
	12H	-3.8	-3.4	-3.4	-3.1	-2.8	-3.8	-3.4	-3.4	-3.1	-2.8
4H	2H	-3.7	-3.2	-3.3	-2.9	-2.6	-3.7	-3.2	-3.3	-2.9	-2.6
	3H	-3.8	-3.4	-3.4	-3.1	-2.8	-3.8	-3.4	-3.4	-3.1	-2.8
	4H	-3.9	-3.6	-3.5	-3.2	-2.8	-3.9	-3.6	-3.5	-3.2	-2.8
	6H	-4.0	-3.7	-3.6	-3.3	-2.9	-4.0	-3.7	-3.6	-3.3	-2.9
	8H	-4.0	-3.8	-3.6	-3.4	-2.9	-4.0	-3.8	-3.6	-3.4	-2.9
	12H	-4.1	-3.8	-3.6	-3.4	-3.0	-4.1	-3.8	-3.6	-3.4	-3.0
8H	4H	-4.0	-3.8	-3.6	-3.4	-2.9	-4.0	-3.8	-3.6	-3.4	-2.9
	6H	-4.1	-3.9	-3.7	-3.5	-3.0	-4.1	-3.9	-3.7	-3.5	-3.0
	8H	-4.2	-4.0	-3.7	-3.5	-3.0	-4.2	-4.0	-3.7	-3.5	-3.0
	12H	-4.2	-4.1	-3.7	-3.6	-3.1	-4.2	-4.1	-3.7	-3.6	-3.1
12H	4H	-4.1	-3.8	-3.6	-3.4	-3.0	-4.1	-3.8	-3.6	-3.4	-3.0
	6H	-4.2	-4.0	-3.7	-3.5	-3.0	-4.2	-4.0	-3.7	-3.5	-3.0
	8H	-4.2	-4.1	-3.7	-3.6	-3.1	-4.2	-4.1	-3.7	-3.6	-3.1
Variations with the observer position at spacing:											
S =		1.0H	0.8 / -18.5				0.8 / -18.5				
		1.5H	9.6 / -18.7				9.6 / -18.7				
		2.0H	11.6 / -23.0				11.6 / -23.0				