Design iGuzzini iGuzzini

Last information update: May 2025

Product configuration: QT00

QT00: MInimal Ø 174 - Wide Flood beam - LED



Product code

QT00: MInimal Ø 174 - Wide Flood beam - LED

Technical description

Ring luminaire with 18 optical elements for LED lamps - fixed optics. The optic system guarantees a high level of visual comfort and no glare. The body includes a radiant surface made of die-cast aluminium. Minimal (frameless) version for flush with ceiling installation. For recessed installation in a false ceiling a specific adapter is required that is available with a separate item code. High definition reflectors made of thermoplastic material vacuum-metallised with aluminium vapours, integrated in a set-back position in the anti-glare screen. Supplied with a power supply unit connected to the luminaire.

Installation

Recessed with steel wire springs for false ceilings from 12,5 to 25 mm thick - Ø 174 installation hole.



White (01) | Black (04) | Gold (14)* | Burnished chrome (E6)*

Weight (Kg)

0.68



Mounting

ceiling recessed

Wiring

On the power supply unit with terminal board included. Available in DALI electronic versions.

Complies with EN60598-1 and pertinent regulations







On the visible part of the product once installed



C€















Technical data

Im system:	2772	Colour temperature [K]:	3000
W system:	39.1	MacAdam Step:	2
Im source:	3300	Life Time LED 1:	50,000h - L90 - B10 (Ta 25°C)
W source:	36	Voltage [Vin]:	230
Luminous efficiency (lm/W,	70.9	Lamp code:	LED
real value):		Number of lamps for optical	1
Im in emergency mode:	-	assembly:	
Total light flux at or above	0	ZVEI Code:	LED
an angle of 90° [Lm]:		Number of optical	1
Light Output Ratio (L.O.R.)	84	assemblies:	
[%]:		Control:	DALI-2
Beam angle [°]:	58°		
CRI (minimum):	90		


Polar

lmax=3476 cd	C50-230		Lux				
90°	0° \ 90°	nL 0.84 100-100-100-100-84	h	d1	d2	Em	Emax
	X	UGR 11.0-10.9 DIN A.61 UTE	2	2.2	2.2	702	868
X X -	\times \wedge	0.84A+0.00T F"1=998	4	4.4	4.4	175	217
3000		F"1+F"2=1000 F"1+F"2+F"3=1000 CIBSE	6	6.7	6.7	78	96
α=58°		LG3 L<1500 cd/m² at 65° UGR<16 L<1500 cd/mq (₆₅ 8	8.9	8.9	44	54

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	76	72	69	67	71	69	68	66	78
1.0	79	76	73	71	75	73	72	70	83
1.5	83	80	78	77	79	78	77	74	89
2.0	86	84	82	81	83	81	80	78	93
2.5	87	86	85	84	85	84	83	80	96
3.0	88	87	86	86	86	85	84	82	98
4.0	89	88	88	87	87	87	85	83	99
5.0	90	89	89	89	88	88	86	84	100

Luminance curve limit



Riflect ceil/ca walls work Room x 2H	pl. n dim y 2H 3H 4H 6H 8H	0.70 0.50 0.20 11.6 11.5 11.4	12.2	0.50 0.50 0.20 viewed crosswise	0.50 0.30 0.20	0.30 0.30 0.20	0.70 0.50 0.20	0.70 0.30 0.20	0.50 0.50 0.20	0.50 0.30 0.20	0.30	
walls work Room x 2H	pl. 1 dim y 2H 3H 4H 6H 8H	0.50 0.20 11.6 11.5	0.30 0.20	0.50 0.20 viewed crosswis	0.30 0.20	0.30	0.50	0.30	0.50	0.30	0.30	
work Room x 2H	pl. 1 dim y 2H 3H 4H 6H 8H	0.20 11.6 11.5	0.20	0.20 viewed crosswis	0.20							
Room x 2H	2H 3H 4H 6H 8H	11.6 11.5	12.2	viewed crosswis		0.20	0.20	0.20	0.20	0.20		
х 2Н	y 2H 3H 4H 6H 8H	11.5	12.2	eiweeon	e						0.20	
2H	2H 3H 4H 6H 8H	11.5	12.2		e		viewed					
Serve II	3H 4H 6H 8H	11.5		110		crosswise						
4H	4H 6H 8H		40.0	11.3	12.5	12.7	11.4	12.0	11.7	12.3	12.	
4H	6H 8H	11.4	12.0	11.8	12.3	12.6	11.3	11.8	11.6	12.1	12.	
4H	8H		11.9	11.8	12.2	12.5	11.2	11.7	11.6	12.0	12.	
4H		11.3	11.8	11.7	12.1	12.4	11.2	11.6	11.5	11.9	12.	
4H		11.3	11.7	11.7	12.1	12.4	11.1	11.6	11.5	11.9	12.	
4H	12H	11.3	11.7	11.6	12.0	12.4	11.1	11.5	11.5	11.8	12.	
	2H	11.4	11.9	11.8	12.2	12.5	11.2	11.7	11.6	12.0	12.	
	ЗН	11.3	11.7	11.6	12.0	12.4	11.1	11.5	11.5	11.8	12.	
	4H	11.2	11.5	11.6	11.9	12.3	11.0	11.4	11.4	11.7	12.	
	6H	11.1	11.4	11.5	11.8	12.2	10.9	11.2	11.3	11.6	12.	
	HS	11.0	11.3	11.5	11.8	12.2	10.9	11.2	11.3	11.6	12.	
	12H	11.0	11.3	11.4	11.7	12.1	10.8	11.1	11.3	11.5	12.	
вн	4H	11.0	11.3	11.5	11.8	12.2	10.9	11.2	11.3	11.6	12.	
	бН	11.0	11.2	11.4	11.6	12.1	10.8	11.0	11.2	11.5	11.	
	HS	10.9	11.1	11.4	11.6	12.1	10.7	10.9	11.2	11.4	11.	
	12H	8.01	11.0	11.3	11.5	12.0	10.7	10.9	11.2	11.3	11.	
12H	4H	11.0	11.3	11.4	11.7	12.1	10.8	11.1	11.3	11.5	12.	
	бН	10.9	11.1	11.4	11.6	12.1	10.7	10.9	11.2	11.4	11.	
	H8	10.8	11.0	11.3	11.5	12.0	10.7	10.9	11.2	11.3	11.	
Variat	tions wi	th the ob	oserverp	noitieo	at spacin	g:						
S =	1.0H	6.9 / -27.9					6.8 / -18.2					
	1.5H	9.7 / -28.2					9.6 / -18.4					