


Last information update: October 2024

Product configuration: Q098

Q098: Fixed circular recessed luminaire - Ø125 mm - warm white - wide flood optic - UGR<19

**Product code**

Q098: Fixed circular recessed luminaire - Ø125 mm - warm white - wide flood optic - UGR<19

Technical description

Fixed round luminaire designed to use a LED lamp with C.O.B. technology. Version with rim for surface-mounting. Reflector vacuum-metallised with aluminium vapours with an anti-scratch protective layer. Die-cast aluminium body and passive dissipation system. Product complete with LED lamp in warm white colour tone (3000K). General light emission, with controlled luminance UGR<19 1500 cd/m² α>65° wide flood optic.

Installation


Recessed using torsion springs which allow easy installation in false ceilings with thickness ranging from 1 mm to 20 mm.

Colour

White / Aluminium (39)

Mounting

ceiling recessed

**Wiring**

product complete with 1-10V components

Complies with EN60598-1 and pertinent regulations




IP20



IP54

On the visible part of
the product once installed**Technical data**


| | | | |
|--|------|---------------------------------------|---------------------------------|
| lm system: | 2145 | CRI (minimum): | 80 |
| W system: | 21.8 | Colour temperature [K]: | 3000 |
| lm source: | 2650 | MacAdam Step: | 2 |
| W source: | 17 | Life Time LED 1: | > 50,000h - L90 - B10 (Ta 25°C) |
| Luminous efficiency (lm/W, real value): | 98.4 | Lamp code: | LED |
| lm in emergency mode: | - | Number of lamps for optical assembly: | 1 |
| Total light flux at or above an angle of 90° [Lm]: | 0 | ZVEI Code: | LED |
| Light Output Ratio (L.O.R.) [%]: | 81 | Number of optical assemblies: | 1 |
| Beam angle [°]: | 64° | Control: | 1-10V |

Polar

Utilisation factors

| R | 77 | 75 | 73 | 71 | 55 | 53 | 33 | 00 | DRR |
|------|----|----|----|----|----|----|----|----|-----|
| K0.8 | 72 | 68 | 65 | 63 | 67 | 64 | 64 | 61 | 76 |
| 1.0 | 75 | 72 | 69 | 67 | 71 | 68 | 68 | 65 | 81 |
| 1.5 | 79 | 77 | 74 | 73 | 76 | 74 | 73 | 70 | 87 |
| 2.0 | 82 | 80 | 78 | 77 | 79 | 77 | 77 | 74 | 92 |
| 2.5 | 84 | 82 | 81 | 80 | 81 | 80 | 79 | 77 | 95 |
| 3.0 | 85 | 84 | 83 | 82 | 82 | 81 | 80 | 78 | 97 |
| 4.0 | 86 | 85 | 84 | 84 | 83 | 83 | 82 | 80 | 98 |
| 5.0 | 86 | 86 | 85 | 85 | 84 | 84 | 82 | 80 | 99 |

Luminance curve limit



UGR diagram

| Corrected UGR values (at 2650 lm bare lamp luminous flux) | | | | | | | | | | | |
|---|-------|------------------|----------|------|------|------|----------------|------|------|------|------|
| Reflect.: | | viewed crosswise | | | | | viewed endwise | | | | |
| ceil/cav | walls | work pl. | Room dim | X | Y | | | | | | |
| 0.70 | 0.70 | 0.50 | 0.50 | 0.30 | | 0.70 | 0.70 | 0.50 | 0.50 | | |
| 0.50 | 0.30 | 0.50 | 0.30 | 0.30 | | 0.50 | 0.30 | 0.50 | 0.30 | | |
| 0.20 | 0.20 | 0.20 | 0.20 | 0.20 | | 0.20 | 0.20 | 0.20 | 0.20 | | |
| 2H | 2H | 19.6 | 20.2 | 19.9 | 20.4 | 20.6 | 19.6 | 20.2 | 19.9 | 20.4 | 20.6 |
| 3H | 19.4 | 20.0 | 19.8 | 20.2 | 20.5 | 19.4 | 20.0 | 19.8 | 20.2 | 20.5 | |
| 4H | 19.4 | 19.9 | 19.7 | 20.1 | 20.4 | 19.4 | 19.9 | 19.7 | 20.1 | 20.4 | |
| 6H | 19.3 | 19.7 | 19.6 | 20.1 | 20.4 | 19.3 | 19.7 | 19.6 | 20.1 | 20.4 | |
| 8H | 19.3 | 19.7 | 19.6 | 20.0 | 20.4 | 19.3 | 19.7 | 19.6 | 20.0 | 20.4 | |
| 12H | 19.2 | 19.6 | 19.6 | 20.0 | 20.3 | 19.2 | 19.6 | 19.6 | 20.0 | 20.3 | |
| 4H | 2H | 19.4 | 19.9 | 19.7 | 20.1 | 20.4 | 19.4 | 19.9 | 19.7 | 20.1 | 20.4 |
| 3H | 19.2 | 19.6 | 19.6 | 20.0 | 20.3 | 19.2 | 19.6 | 19.6 | 20.0 | 20.3 | |
| 4H | 19.1 | 19.5 | 19.5 | 19.9 | 20.2 | 19.1 | 19.5 | 19.5 | 19.9 | 20.2 | |
| 6H | 19.0 | 19.4 | 19.5 | 19.8 | 20.2 | 19.0 | 19.4 | 19.5 | 19.8 | 20.2 | |
| 8H | 19.0 | 19.3 | 19.4 | 19.7 | 20.1 | 19.0 | 19.3 | 19.4 | 19.7 | 20.1 | |
| 12H | 18.9 | 19.2 | 19.4 | 19.6 | 20.1 | 18.9 | 19.2 | 19.4 | 19.6 | 20.1 | |
| 8H | 4H | 19.0 | 19.3 | 19.4 | 19.7 | 20.1 | 19.0 | 19.3 | 19.4 | 19.7 | 20.1 |
| 6H | 18.9 | 19.1 | 19.4 | 19.6 | 20.1 | 18.9 | 19.1 | 19.4 | 19.6 | 20.1 | |
| 8H | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | |
| 12H | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | |
| 12H | 4H | 18.9 | 19.2 | 19.4 | 19.6 | 20.1 | 18.9 | 19.2 | 19.4 | 19.6 | 20.1 |
| 6H | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | |
| 8H | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | 18.8 | 19.0 | 19.3 | 19.5 | 20.0 | |
| Variations with the observer position at spacing: | | | | | | | | | | | |
| S = | 1.0H | 4.7 | / -26.2 | | | 4.7 | / -26.2 | | | | |
| | 1.5H | 7.5 | / -31.2 | | | 7.5 | / -31.2 | | | | |
| | 2.0H | 9.5 | / -31.4 | | | 9.5 | / -31.4 | | | | |