




### Isolux



### UGR diagram

Corrected UGR values (at 2750 lm bare lamp luminous flux)													
Reflect.:		viewed crosswise					viewed endwise						
ceiling/cav													
walls		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30		
work pl.		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30		
Room dim		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20		
x	y												
2H	2H	11.6	13.5	11.9	13.8	14.1	11.6	13.5	11.9	13.8	14.1		
	3H	11.5	12.9	11.9	13.2	13.5	11.5	12.9	11.9	13.2	13.5		
	4H	11.4	12.6	11.8	12.9	13.2	11.5	12.6	11.8	12.9	13.3		
	6H	11.4	12.3	11.8	12.6	13.0	11.4	12.3	11.8	12.6	13.0		
	8H	11.3	12.3	11.7	12.6	13.0	11.4	12.3	11.7	12.6	13.0		
	12H	11.3	12.2	11.7	12.6	13.0	11.3	12.3	11.7	12.6	13.0		
4H	2H	11.5	12.6	11.8	12.9	13.3	11.4	12.6	11.8	12.9	13.2		
	3H	11.3	12.3	11.7	12.7	13.0	11.3	12.3	11.7	12.7	13.0		
	4H	11.2	12.2	11.6	12.6	13.0	11.2	12.2	11.6	12.6	13.0		
	6H	10.9	12.5	11.4	12.9	13.4	10.9	12.5	11.4	12.9	13.4		
	8H	10.8	12.5	11.2	13.0	13.5	10.8	12.5	11.2	13.0	13.5		
	12H	10.7	12.5	11.2	12.9	13.4	10.7	12.5	11.2	12.9	13.5		
8H	4H	10.8	12.5	11.2	13.0	13.5	10.8	12.5	11.2	13.0	13.5		
	6H	10.7	12.3	11.2	12.8	13.3	10.7	12.3	11.2	12.8	13.3		
	8H	10.7	12.0	11.2	12.5	13.1	10.7	12.0	11.2	12.5	13.1		
	12H	10.8	11.7	11.3	12.2	12.7	10.8	11.7	11.3	12.2	12.7		
12H	4H	10.7	12.5	11.2	12.9	13.5	10.7	12.5	11.2	12.9	13.4		
	6H	10.7	12.0	11.2	12.5	13.1	10.7	12.0	11.2	12.5	13.1		
	8H	10.8	11.7	11.3	12.2	12.7	10.8	11.7	11.3	12.2	12.7		
Variations with the observer position at spacing:													
S =		1.0H	2.4 / -0.6				2.4 / -0.6						
		1.5H	4.6 / -9.5				4.6 / -9.5						
		2.0H	6.6 / -11.8				6.6 / -11.8						